

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

35609

WRD-2
 7/69

WELL COMPLETION REPORT

Permit Number: 35609
 Name of Well: Martha's Home
Stephens Pass
 Observation Well
 Production Well
 Well Abandoned? Yes No
 Total Well Depth 49 feet
 Date Completed 4-5-76
 Casing: Type NO. 10
 from 0 feet to 49 feet
 from 0 feet to 49 feet
 Casing: Type 2" PVC
0 inches to 49 feet
0 inches to 49 feet
 Drive Shoe? Yes No
 Screen Setting:
44 feet to 49 feet
 Level Packed? Yes No
44 feet to 49 feet
 Well Log

3. Well Head Completion:
 Adapter None Type _____
8 inches above grade
 9. Static Water Level:
8 feet below grade
 _____ feet above grade
 10. Pumping Water Level:
12 feet below grade after
2 hours at 60 GPM
 11. Permanent Pump Installed?
 Yes No
 a. Shallow Well _____
 Deep Well _____
 b. Reciprocating _____ Rotary _____
 Centrifugal _____ Jet _____
 Submersible _____
 c. Capacity _____ GPM
 12. Well Number _____
 (Leave Blank)

Rd 21-09

Formation	Thickness of Stratum	Depth to Bottom of Stratum
fine yellow sand	20'	20'
medium coarse red sand	10'	30'
medium fine white sand	10'	40'
coarse yellow sand	9'	49'