

MAY 24 1970

WATER AND AIR RESOURCES COMMISSION
Water Resources Division
Dover, Delaware 19901

712

STATE OF DELAWARE
WATER RESOURCES SECTION

WELL COMPLETION REPORT

1. Permit Number: 35872

NAME OF WELL:

Blue Spring

2. Well Head Completion:

12 inches above grade
feet above grade

3. Type Well

Observation Well

Production Well

Well Completion: Yes No

4. Static Water Level:

10 feet below grade
feet above grade

5. Total Well Depth 60 feet

Date Completed 5-6-70

6. Pumping Water Level:

19 feet below grade after
1 hour at 25 GPM

7. Grout: Type Cement

from 3 feet to 15 feet

from _____ feet to _____ feet

8. Permanent Pump Installed?

Yes No

a. Shallow Well

Deep Well

b. Reciprocating Rotary

Centrifugal Jet

Submersible

c. Capacity _____ GPM

9. Casing: Type Open

0 inches to 55 feet

inches to _____ feet

Drive Shoe? Yes No

10. Well Number

(Leave Blank)

-Screen Setting:

55 feet to 60 feet

11. Gravel Facked? Yes No

55 feet to 60 feet

Rd 31-21

12. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Top soil	0	1
fill dirt	1	2
brown clay	2	18
lt tan sand - med	18	25
light sand - med	2	3
lt tan sand - med	30	52
brown sand - coarse	52	60

Signature of Water Well Contractor _____ Date _____