

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

WRD-2
 WATER RESOURCES DIVISION
 MAR 2 1977

WELL COMPLETION REPORT

1. Permit Number: 37625
 Owner of Well: Dot Bayinger

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 48 feet
 Date Completed 2-16-77

4. Grout: Type Cement
 from 3 feet to 15 feet
 from feet to feet

5. Casing: Type PVC
0 inches to 43 feet
 inches to feet
 Drive Shoe? Yes No

6. Screen Setting:
43 feet to 48 feet

7. Gravel Packed? Yes No
41 feet to 44 feet

8. Well Head Completion:
No Pitless Adapter inches above grade

9. Static Water Level:
9 feet below grade
 feet above grade

10. Pumping Water Level:
15 feet below grade after
1 hour at 60 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Date Submersible
 c. Capacity GPM

12. Well Number
 (Leave Blank)

Rd 33-05

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
top soil	0	1
top clay	1	8
top sandy clay	8	14
top sand - fine	14	18
to top sand - Med. fine	18	42
top sand - Med	42	48