

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

WRD-2
 7/69
 WATER SUPPLY

MAR 8 1

WELL COMPLETION REPORT

1. Permit Number: <u>37626</u> Owner of Well: <u>Dot Saperger</u>	8. Well Head Completion: <u>No</u> Pitless Adapter _____ Type _____ _____ inches above grade
2. Test Well Observation Well _____ Production Well <input checked="" type="checkbox"/> Well Abandoned? Yes _____ No _____	9. Static Water Level: <u>9</u> feet below grade _____ feet above grade
3. Total Well Depth <u>48</u> feet Date Completed <u>2-23-77</u>	10. Pumping Water Level: <u>15</u> feet below grade after <u>1</u> hour at <u>60</u> GPM
4. Grout: Type <u>Cement</u> from <u>3</u> feet to <u>15</u> feet from _____ feet to _____ feet	11. Permanent Pump Installed? Yes _____ No <input checked="" type="checkbox"/> a. Shallow Well _____ Deep Well _____ b. Reciprocating _____ Rotary _____ Centrifugal _____ Jet _____ Submersible _____ c. Capacity _____ GPM
5. Casing: Type <u>PVC</u> <u>0</u> inches to <u>43</u> feet _____ inches to _____ feet Drive Shoe? Yes _____ No <input checked="" type="checkbox"/>	12. Well Number _____ (Leave Blank)
6. Screen Setting: <u>43</u> feet to <u>48</u> feet	
7. Gravel Packed? Yes <input checked="" type="checkbox"/> No _____ <u>41</u> feet to <u>48</u> feet	
13. Well Log	

Rd 33-06

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Top soil	0	1
Thin clay	1	8
Thin clay	8	10
to Tan sand - fine	10	15
with sand Med	15	40
Thin sand Med	40	48