WATER SUPPLY SECTION
DIVISION OF WATER RESOURCES
89 KINGS HIGHWAY
DOVER, DELAWARE 19901
PHONE: 302-739-3665
FAX: 302-739-2296

STATE OF DELAWARE DEPARTMENT OF NATURAL RESOURCES AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST BE RETURNED WITHIN 30 DAYS OF CONSTRUCTION DATE

FORMATION LOG

Rd35-19

PAGE _____ OF ____ PAGES

PLEASE PRINT OR TYPE - ILLEGIBLE OR INCOMPLETE FORMS WILL BE RETURNED			
PERMIT# 176371	LOCAL ID#		
PROPERTY OWNER RANDALL CATHELL			
WELL CONTRACTOR SOMERSET WELL DRILLING GO. INC.		LIC# 4033	
DESCRIPTION	ТО	P OF STRATA	BOTTOM OF STRATA
SURFACE SOIL		0	5
YEILOW CLAY		5	7
GOLD SAND GRAVEL		7	14
WHITE CLAY		14	17
TAN SAND & GRAVEL		17	75
			· · ·
OTHER COMMENTS: SET WELL 2" X 75 ft. WITH 10	ft. # .010 SLOT	SCREEN	
		BECEN	
		TED () 1	2001
		WATER SE	78 8 8 8
I HEREBY AFFIRM THE INFORMATION I HAVE SUBMITTED IS ACC	CURATE AND CORRECT	Γ	
gy chall T. Hall	4034		129/01
Signature of Well Driller In Charge	License#	Date	