

1. Permit Number: 26915
 Owner of Well: James Phair

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 80 feet
 Date Completed 9-21-76

4. Grout: Type PUMICE
 from 3 feet to 15 feet
 from feet to feet

5. Casing: Type PVC
0 inches to 75 feet
 inches to feet
 Drive Shaft? Yes No

6. Screen Setting:
15 feet to 80 feet

7. Gravel Packed? Yes No
12 feet to 80 feet

13. Well Log

8. Well Head Completion:
NO Pitless Adapter Type
 inches above grade

9. Static Water Level:
10 feet below grade
 feet above grade

10. Pumping Water Level:
18 feet below grade after
1 hours at 65 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity GPM

12. Well Number
 (Leave Blank)

De 21-02

Formation	Thickness of Stratum	Depth to Bottom of Stratum
top soil	0	1
yellow sand - fine	7	10
tan clay	10	15
lt tan sand - med	15	35
tan med. med fine	35	45
lt tan med med	45	70
tan med - med	70	80

14. Signature of Water Well Contractor Date