

WELL COMPLETION REPORT

1. Permit Number: 38960
 Owner of Well: R. W. Stuard, R. W. R. R.
Raymond Wesleyon C. Birch

2. Test Well: Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 75 feet
 Date Completed Aug 5 1977

4. Grout: Type Cement
 from 0 feet to 20 feet
 from feet to feet

5. Casing: Type PVC Section
2 inches to 65 feet
 inches to feet
 Drive Shoe? Yes No

6. Screen Setting:
65 feet to 75 feet

7. Gravel Packed? Yes No
65 feet to 75 feet

8. Well Head Completion: 8 inches above grade
 Pileless Adapter Type

9. Static Water Level:
11 feet below grade
0 feet above grade

10. Pumping Water Level:
21 feet below grade after 15 GPM
2 hours at 15 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity 5 GPM
 12. Well Number
 (Leave Blank)

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
<u>Sand</u>	<u>5</u>	<u>5</u>
<u>white clay</u>	<u>10</u>	<u>15</u>
<u>gray clay and shells</u>	<u>25</u>	<u>40</u>
<u>Dark Gray Clay</u>	<u>25</u>	<u>65</u>
<u>Sand and wood chips</u>	<u>10</u>	<u>75</u>