

STATE OF DELAWARE
WATER AND AIR RESOURCES COMMISSION
Water Resources Division
Dover, Delaware 19901

WELL COMPLETION REPORT

1. Permit Number: 36045
 Owner of Well: Carl Simpson

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 97 feet
 Date Completed 6-18-76

4. Grout: Type none
 from feet to feet
 from feet to feet

5. Casing: Type 2" PVC feet
0 inches to feet
rive shoe? Yes No

6. Screen Setting: 87 feet to 97 feet

7. Gravel Packed? Yes No
87 feet to 97 feet

8. Well Head Completion: Type
 Pitless Adapter inches above grade

9. Static Water Level:
20 feet below grade
 feet above grade

10. Pumping Water Level:
84 feet below grade after 45 GPM
 hours at GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity GPM
 12. Well Number
 (Leave Blank)

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
	<u>10'</u>	<u>10'</u>
<u>lime light brown sand</u>	<u>10'</u>	<u>20'</u>
<u>gray sand</u>	<u>10'</u>	<u>30'</u>
<u>" " " and shells</u>	<u>10'</u>	<u>40'</u>
<u>" " " blue clay</u>	<u>10'</u>	<u>50'</u>
<u>medium brown "</u>	<u>20'</u>	<u>70'</u>
<u>" white "</u>	<u>10'</u>	<u>80'</u>
<u>" yellow "</u>	<u>10'</u>	<u>90'</u>
<u>green white "</u>	<u>10'</u>	<u>94'</u>