WELL COMPLETION REPORT

57336

1/5/2026

(illegible), Colorado

6-19-84

TEST ☒ PERMANENT

ESTIC ☒ AGRICULTURAL
MMERCIAL ☐ INDUSTRIAL
GATION ☐ PUBLIC
NITOR ☐ DEWATERING
PUMP RECHARGE ☐ HEAT PUMP SUPPLY
IER (Specify) _____

PLACEMENT WELL? YES ☐ NO ☒
NT DATE FOR OLD WELL _____
NT METHOD _____

DRILLING METHOD

☐ BORED ☐ CABLE TOOL
☒ DRILLED ☐ AIR ROTARY
ARY ☐ REVERSE ☐ WASHED
(Specify) _____
DRILLED 95

CASING SEQUENCE

	1st	2nd	3rd	4th
	0			
TO	35			
METER	2			
ERIAL	PVC			

SCREEN SEQUENCE

	1st	2nd	3rd	4th
	85			
TOM	95			
METER	2			
TERIAL	PVC			

WRITTEN APPROVAL FOR SCREENING/GRAVEL PACKING MORE THAN ONE AQUIFER MUST BE OBTAINED FROM DWREC

CEMENT ☐ BENTONITE CLAY ☐

_____ TO 25 FEET

BACKFILL OF WELL ANNULUS
GRAVEL FROM 25 TO 85 FEET
PACK TYPE 3/32"
85 TO 95 FEET
WATER LEVEL DATE 6-19-84
(flow) (above) GROUND SURFACE
WATER LEVEL 20 FT. BELOW GRADE
2 HOURS AT 60 GPM

WELL COMPLETION:

☐ CAPTOR ☐

FT. ABOVE GRADE

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE _____
RATED CAPACITY (GPM) _____
PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?

	YES	NO
A. AT LEAST 5' FROM ANY OVERHANG	☒	☐
B. AT LEAST 50' FROM ANY SEPTIC TANK	☒	☐
C. AT LEAST 10' FROM TOWN SEWER LINE	☒	☐
D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD	☒	☐

No

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC · (TILE FIELD) · CESSPOOL OR PRIVY
IS 1000 ± FROM COMPLETED WELL.
IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM? ☒ ☐
IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS

Rh25-01

DRILLER'S LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
top soil	1	1
white clay sand	2	3
Dan Moran	3	79
Sand & gravel	79	96
Shale	96	100

SUPPLEMENTAL DRILLER'S LOG ATTACHED YES ☐ NO ☐
PAGE 1 OF 1 PAGES
COMPANY NAME Pete Lininger Co.
SIGNATURE OF DRILLER IN CHARGE Pete Lininger DATE 8/24/84