

MAIL 10:

WATER SUPPLY SECTION
DIVISION OF WATER RESOURCES
89 KINGS HIGHWAY
DOVER, DELAWARE 19901
PHONE: 302-739-3665
FAX: 302-739-2296

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
BE RETURNED WITHIN 30 DAYS OF
CONSTRUCTION DATE

FORMATION LOG

R-18-14

PAGE 1 OF 1 PAGES

PLEASE PRINT OR TYPE - ILLEGIBLE OR INCOMPLETE FORMS WILL BE RETURNED

PERMIT#	184989, 185011, 185013 - 016		LOCAL ID#	OB-1, 2, 3, 5, 7, 8 9	
PROPERTY OWNER	Gulf Stream Development Corp.				
WELL CONTRACTOR	Stephens Environmental / WALTON Corp		LIC#	52	
	DESCRIPTION		TOP OF STRATA		BOTTOM OF STRATA
	root mat / topsoil		6.5'		1.5'
	Very pale brown / light yellowish brown, moist, fine to medium sand, trace of silt		1.5'		4.0'
	light yellowish brown / brownish yellow, wet to saturated, fine to medium sand, trace of silt		4.0'		8.5'
	Very dark gray / black, wet, silty fine to medium sand, trace to some shells, trace of clay		8.5'		9.0'

OTHER COMMENTS:

RECEIVED
1 MAY 20 2002
WATER SUPPLY

I HEREBY AFFIRM THE INFORMATION I HAVE SUBMITTED IS ACCURATE AND CORRECT

Ray A. Arriaga Signature of Well Driller In Charge 1043 License# 4/10/02 Date