

WELL COMPLETION REPORT

56607

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE _____
RATED CAPACITY (GPM) _____
PUMP INTAKE SETTING _____ FEET BELOW GRADE

THE COMPLETED WELL IS?

- A. AT LEAST 5' FROM ANY OVERHANG YES NO
- B. AT LEAST 50' FROM ANY SEPTIC TANK YES NO
- C. AT LEAST 10' FROM TOWN SEWER LINE YES NO
- D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD YES NO

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY
IS 200 FEET FROM COMPLETED WELL.

IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM? YES NO

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

56607
Renwick Sound Inc.

STRUCTURE DATE: 5/22/84
NOSE TEST: PERMANENT

- DOMESTIC
- COMMERCIAL
- IRRIGATION
- MONITOR
- HEAT PUMP RECHARGE
- OTHER (Specify) _____
- AGRICULTURAL
- INDUSTRIAL
- PUBLIC
- DEWATERING
- HEAT PUMP SUPPLY

IS A REPLACEMENT WELL? YES NO
ABANDONMENT DATE FOR OLD WELL: _____
ABANDONMENT METHOD: _____

DRILLING METHOD

- AUGERED
- BORED
- CABLE TOOL
- DRIVEN
- JETTED
- AIR ROTARY
- MUD ROTARY
- REVERSE
- WASHED

OTHER (Specify): _____
TOTAL DEPTH DRILLED: 65'

CASING SEQUENCE

1st	2nd	3rd	4th
2'	19'		
79'	55'		
4"	4"		
STEEL PVC			

SCREEN SEQUENCE

1st	2nd	3rd	4th
55'			
65'			
4"			
PVC			

WRITTEN APPROVAL FOR SCREENING GRAVEL PACKING MORE THAN ONE AQUIFER MUST BE OBTAINED FROM DNR/EC

CEMENT TYPE: CEMENT BENTONITE CLAY

DEPTH: 0 TO 30 FEET
WITHOUT BACKFILL OF WELL ANNULUS
FROM _____ TO _____ FEET

WELL PACK TYPE: AGRIC IF
DEPTH: 30 TO 65 FEET

STATIC WATER LEVEL DATE: 5/22/84
2 FT. (Below, above) GROUND SURFACE
RING WATER LEVEL: 7 FT. BELOW GRADE
TEST: 2 HOURS AT 40 GPM

WELL HEAD COMPLETION:

WELL HEAD ADAPTOR:
TYPE: cupped
HEIGHT: _____ INCHES ABOVE GRADE

04/06/00
TAK

205(1)
(E)

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Sep soil	0	1
White fn/red sand	1	15
Gry fn sand w/gry cly	15	32
Wht fn/crs sand	32	70

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO

DATE: _____ PAGES: _____
COMPANY NAME: Delaerwa Drilling Co.
SIGNATURE OF DRILLER IN CHARGE: Calvin Walker
DATE: 6/2/84