

DATE 6/4/88
 EST PERMANENT
 AGRICULTURAL
 INDUSTRIAL
 PUBLIC
 DEWATERING
 HEAT PUMP SUPPLY
 Specify _____
 ELEMENT WELL? YES NO
 DATE FOR OLD WELL N/A
 METHOD N/A

PUMP MANUFACTURE N/A
 RATED CAPACITY (GPM) _____
 PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?
 YES NO
 A. AT LEAST 15' FROM ANY FOUNDATION
 B. AT LEAST 50' FROM ANY SEPTIC TANK
 C. AT LEAST 10' FROM TOWN SEWER LINE
 D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD

THE NEAREST NEIGHBORS (CIRCLE ONE)
 SEPTIC TILE FIELD CESSPOOL OR PRIVY
 IS 100' FROM COMPLETED WELL.
 IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

DRILLING METHOD
 BORED CABLE TOOL
 JETTED AIR ROTARY
 REVERSE WASHED

DEPTH 70'

CASING SEQUENCE

INNER	OUTER
2'	
62'	
2" PVC	

SCREEN SEQUENCE

INNER	OUTER
60'	
70'	
2" PVC	

WRITTEN APPROVAL FOR SCREENING/ GRAVEL PACKING MORE THAN ONE FOOT DEEP MUST BE OBTAINED FROM INDEC.

MENT BENTONITE CLAY
 TO 20 FEET
 KILL OF WELL ANNULUS
 FROM _____ TO _____ FEET
 TYPE MARIE #2
 TO 70 FEET
 LEVEL DATE 6/4/88
 (above) GROUND SURFACE
 LEVEL 43 FT. BELOW GRADE
 HOURS AT 70 GPM.

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Fine light gray sand	0	10
Fine med light gray sand	10	30
med-light coarse sand	30	40
med-coarse sand	40	50
med-coarse sand	50	60
med-coarse sand	60	70

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
 PAGE 1 OF 1 PAGES
 COMPANY NAME Delmarva Drilling Co.
 SIGNATURE OF DRILLER IN CHARGE Kevin Zell DATE 6/4/88

