

WINDSOR

10-17-88

PERMANENT

AGRICULTURAL

INDUSTRIAL

PUBLIC

DEWATERING

HEAT PUMP SUPPLY

ARGE

WELL? YES NO

OLD WELL N/A

N/A

DRILLING METHOD

BORED CABLE TOOL

JETTED AIR ROTARY

REVERSE WASHED

~~70~~ 70

DRILLING SEQUENCE

INNER	OUTER
BASE GRADE	
140 PVC	

FINISH SEQUENCE

INNER	OUTER
140 PVC	

WRITTEN APPROVAL FOR SCREENING/ GRAVEL PACKING MORE THAN ONE ADJUTER MUST BE OBTAINED FROM DNREC

BENTONITE CLAY

35 FEET

WELL ANNULUS

35 TO 60 FEET

DEPTH 142

70 FEET

DATE 10-17-88

GROUND SURFACE

11 FT BELOW GRADE

AT 60 GPM

REMARKS:

DRILLING

PACKING

GRADE

PUMP MANUFACTURE

RATED CAPACITY (GPM)

N/A

PUMP INTAKE SETTING

11 FT BELOW GRADE

THE COMPLETED WELL IS?

A. AT LEAST 15' FROM ANY FOUNDATION

YES NO

B. AT LEAST 50' FROM ANY SEPTIC TANK

C. AT LEAST 10' FROM TOWN SEWER LINE

D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD

76034

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TLE FIELD CESSPOOL OR PRIVY

IS 100' FROM COMPLETED WELL.

SEWER LATERAL

IS COMPLETED WELL LOCATED AS SHOWN

ON APPLICATION FORM?

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

R:24-13

OCT 25 1988

JAN

DRILLERS LOG DESCRIPTION TOP OF STRATA BOTTOM OF STRATA

<u>Impair</u>	<u>0</u>	<u>1</u>
<u>loam od fine</u>	<u>1</u>	<u>3</u>
<u>loam clay</u>	<u>3</u>	<u>6</u>
<u>lt to od med</u>	<u>6</u>	<u>14</u>
<u>gray clay</u>	<u>14</u>	<u>16</u>
<u>light od med clay</u>	<u>16</u>	<u>35</u>
<u>gray od med</u>	<u>35</u>	<u>55</u>
<u>lo od med</u>	<u>55</u>	<u>60</u>
<u>lo od med</u>	<u>60</u>	<u>70</u>

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO

PAGE 1 OF 1 PAGES

COMPANY NAME LARSON WELLS, Inc.

SIGNATURE OF DRILLER IN CHARGE

DATE

John Staffin

10-24-88

WHITE - DNREC

CANARY - CONTRACTOR

PINK - OWNER