

ATTN: EARL + MARGARET

DATE 6-10-88

TEST PERMANENT

PURPOSE AGRICULTURAL

INDUSTRIAL

PUBLIC

DEWATERING

HEAT PUMP SUPPLY

REPLACEMENT WELL? YES NO

DATE FOR OLD WELL N/A

DRILLING METHOD N/A

DRILLING METHOD

- BORED
- JETTED
- REVERSE
- CABLE TOOL
- AIR ROTARY
- WASHED

DRILLED 60'

CASING SEQUENCE

INNER	OUTER
2' ABOVE GRADE	
57'	
2"	
SCH 40 PVC	

SCREEN SEQUENCE

INNER	OUTER
57'	
62'	
2"	
SCH 40 PVC	

WRITTEN APPROVAL FOR SCREENING/ GRAVEL PACKING MORE THAN ONE FOOT IFER MUST BE OBTAINED FROM DNREC.

CEMENT BENTONITE CLAY

TO 20 FEET

BACKFILL OF WELL ANNULUS 20 TO 50 FEET

TYPE MORE 1 & 2

TO 62 FEET

DATE 6-10-88

FLOW, ABOVE) GROUND SURFACE

FEET LEVEL: 15 FT. BELOW GRADE

HOURS AT 70 GPM.

COMPLETION: SS ADAPTOR CASING

FEET ABOVE GRADE.

PUMP MANUFACTURE _____

RATED CAPACITY (GPM) N/A

PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?

- 673915
- A. AT LEAST 10' FROM ANY FOUNDATION YES NO
 - B. AT LEAST 50' FROM ANY SEPTIC TANK YES NO
 - C. AT LEAST 10' FROM TOWN SEWER LINE YES NO
 - D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD YES NO

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY

IS _____ FROM COMPLETED WELL

IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

CITY SEWAGE

RECEIVED

JUN 23 1988
w

WATER SUPPLY

R:24-16

DRILLER'S LOG DESCRIPTION TOP OF STRATA BOTTOM OF STRATA

DRILLER'S LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Topsoil	0	1
brn clay	1	2
lt gray sd med	2	12
grly clay sd	12	30
lt gray sd med	30	50
lt gray sd med	50	62

SUPPLEMENTAL DRILLER'S LOG ATTACHED YES NO

PAGE 1 OF 1 PAGES

COMPANY NAME LORSON WELLS, INC.

SIGNATURE OF DRILLER IN CHARGE John Huffer DATE 6-20-88