

NOV 17 1975
STATE OF DELAWARE
WATER RESOURCES DIVISION

STATE OF DELAWARE
WATER AND AIR RESOURCES COMMISSION
Water Resources Division
Dover, Delaware 19901

RECEIVED
WRD-2
NOV 20 1975
DELAWARE GEOLOGICAL
SURVEY

WELL COMPLETION REPORT

1. Permit Number: 34861
Owner of Well: Burton Nursery

2. Test Well
Observation Well
Production Well ✓
Well Abandoned? Yes No

3. Total Well Depth 97 feet
Date Completed 11-5-75

4. Grout: Type Concrete
from 35 feet to 50 feet
from feet to feet

5. Casing: Type PVC
0 inches to 87 feet
 inches to feet
Drive Shoe? Yes No X

6. Screen Setting:
87 feet to 97 feet

7. Gravel Packed? Yes ✓ No
85 feet to 97 feet

13. Well Log

8. Well Head Completion:
NO Pitless Adapter Type
 inches above grade

9. Static Water Level:
10 feet below grade
 feet above grade

10. Pumping Water Level:
18 feet below grade after
1 hours at 80 GPM

11. Permanent Pump Installed?
Yes No X
a. Shallow Well
 Deep Well
b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
c. Capacity GPM

12. Well Number
(Leave Blank)

location map on back
R-32-9
A112

Formation	Thickness of Stratum	Depth to Bottom of Stratum
fill dirt	0	1
brn clay	1	14
brn sand-med	14	30
gray clay	30	35
brn sand-med	35	45
brn sand-med fine	45	85
lt brn sand-med coarse	85	97

14. Signature of Water Well Contractor Ideal Well Drillers Date 11-14-75