

R 33-14

A.C. SCHULTES OF DELAWARE, INC.
 P.O. BOX 188 · BRIDGEVILLE, DE 19833

PHONE: 302-337-8254
 FAX: 302-337-8234

DRILLER'S LOG

CUSTOMER: AMERICANA BAYSIDE c/o CARL M. FREEMAN DEVELOPMENT **JOB #:** 2626
ADDRESS: 400 FREEPORT COURT, BETHANY BEACH, DE, 19930 **DATE:** 3/7/00
LOCATION: CR 395, FENWICK ISLAND, DE (SITE #2)

FT FROM GROUND		WELL LOG	
GROUND	SURFACE 0 TO		
	2'	CASING	TOPSOIL
400'	0-1'		FINE TAN SAND
	1-21'		FINE GRAY SAND W/CLAY
	21-33'		MED-COARSE ORANGE SAND
	33-40'		MED-COARSE ORANGE SAND W/GRAVEL
	40-55'		FINE TAN SAND
	55-95'		FINE TAN SAND
	95-101'		GRAY CLAY W/SAND
	101-109'		MED TAN SAND
	109-231'		GRAY SAND W/CLAY
	231-263'		FINE GRAY SAND
	263-280'		FINE GRAY SAND W/CLAY
	280-314'		BROWN CLAY W/SAND
	314-325'		BROWN CLAY
	325-330'		FINE TAN SAND W/CLAY
	330-339'		FINE TAN SAND
	339-400'		

WELL NO:	TW #2	PUMPED WITH:	SUB TEST PUMP	SLOT SIZE:	.020
WELL DIAMETER:	6"	CASING DIAMETER:	6"	SCREEN DIAMETER:	6"
WELL DEPTH:	400'	CASING TYPE:	PVC	SCREEN TYPE:	PVC
STATIC LEVEL:	+2' (flowing)	CASING DEPTH:	350'	SCREEN LENGTH:	50'
PUMPING LEVEL:	24.9'	GROUT TYPE:	CLAY	GRAVEL SIZE:	#1
TEST CAPACITY:	200	GROUT DEPTH:	0-320'	GRAVEL DEPTH:	320-400'
SPEC. CAPACITY:	7.43	GROUT AMOUNT:	20 BAGS	GRAVEL AMOUNT:	30 BAGS
HRS PUMPED:	24	DRILLING RIG:	D-5		

PERMIT #: 170371 **FOREMAN:** S. WILLEY **HELPER:** T. JOHNSON