



MAIL TO:

WATER SUPPLY SECTION
DIVISION OF WATER RESOURCES
89 KINGS HIGHWAY
DOVER, DELAWARE 19901
PHONE: 302-739-3665
FAX: 302-739-2296

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
BE RETURNED WITHIN 30 DAYS OF
CONSTRUCTION DATE

FORMATION LOG

R:33-28

PAGE 2 OF 2 PAGES

PLEASE PRINT OR TYPE - ILLEGIBLE OR INCOMPLETE FORMS WILL BE RETURNED

PERMIT#	170365	LOCAL ID#	OBS 2
PROPERTY OWNER	CMF Bayside LLC		
WELL CONTRACTOR	ACSD	LIC#	14
	DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
	Top Soil	0	1
	Fine-coarse tan sand, gravel & stone <i>Holocene ridge</i>	1	23
	Med-coarse white sand + gravel	Td 23	51
	Med-coarse org sand + gravel	51	80
	Gravel	80	90
	Clay + Gravel	90	101
	Med-coarse gray sand + gravel	101	165
	Fine sand + clay	165	177
	Med-coarse gray sand	177	234
	Fine sand + clay	234	245
	Fine-med gray sand	245	300
	Fine sand + clay	300	315
	Fine-med gray sand	Tc+tb 315	370
	Fine sand + clay	Tc+ta 370	380
	At II		

Q3

70

see also
R:33-20
- pilot hole

OTHER COMMENTS:

RECEIVED
MAR 03 2000
WATER SUPPLY

I HEREBY AFFIRM THE INFORMATION I HAVE SUBMITTED IS ACCURATE AND CORRECT

Signature of Well Driller In Charge: Steven E. Draper License#: 903 Date: 2/28/00