

12/27/85

PLEASE PRINT

PERMIT NO. 62688E LOCAL ID _____

OWNER Capri Yards, Inc. Community Association, Dept. Manager

CONSTRUCTION DATE 10/5/85 PERMANENT TEST

USE: DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO
 ABANDONMENT DATE FOR OLD WELL _____
 ABANDONMENT METHOD _____

DRILLING METHOD
 AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____
 TOTAL DEPTH DRILLED 305'

CASING SEQUENCE

| | |
|---------|-----------|
| 0-21' | 5/8" PIPE |
| 21-305' | 4" PIPE |

SCREEN SEQUENCE

| | |
|------|-----------|
| 305' | 5/8" PIPE |
| 305' | 4" PIPE |

WRITTEN APPROVAL FOR SCREENING/ GRAVEL PACKING MORE THAN ONE FOOT PER FOOT MUST BE OBTAINED FROM STATE.

GROUT TYPE: CEMENT BENTONITE CLAY
 OTHER: _____
 FROM 0 TO 290 FEET
 NON-GROUT PACKING OF WELL ANNULUS
 TYPE GRAVEL FROM 190 TO 305 FEET
 GRAVEL PACK: TYPE MOULDED
 FROM 305 TO 305 FEET
 STATIC WATER LEVEL: DATE 10/5/85
1 FT. (BELOW, ABOVE) GROUND SURFACE
 PUMPING WATER LEVEL: 50 FT. BELOW GRADE
 AFTER _____ HOURS AT _____ GPM

WELL HEAD COMPLETION:
 TYPE: FITLESS ADAPTOR
 OTHER
2 1/2 INCHES ABOVE GRADE

TYPE OF PERMANENT PUMP INSTALLED: _____
 PUMP MANUFACTURE N/A
 RATED CAPACITY (GPM) _____
 PUMP INTAKE SETTING _____ FT. BELOW GRADE
 THE COMPLETED WELL IS?

- A. AT LEAST 5' FROM ANY OVERHANG YES NO
 B. AT LEAST 50' FROM ANY SEPTIC TANK YES NO
 C. AT LEAST 10' FROM TOWN SEWER LINE YES NO
 D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD YES NO

THE NEAREST NEIGHBORS (CIRCLE ONE)
 SEPTIC TILE FIELD CESSPOOL OR PRIVY
 IS 50' FROM COMPLETED WELL
 IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENT

RJ31-08

REF. FIXED
 DEC 27 1985
 WATER SUPPLY.

DRILLERS LOG DESCRIPTION TOP OF STRATA BOTTOM OF

| | | |
|---------------------------|-----|-----|
| Top Soil | 0 | 1 |
| Fine to med sand | 1 | 21 |
| Fine to med sand w/ clay | 21 | NS |
| Fine to coarse gravel | NS | 180 |
| Fine sand w/ clay | 120 | 110 |
| Fine to med sand | 180 | 230 |
| Fine to med sand | 230 | 260 |
| Fine sand w/ clay | 260 | 300 |
| Fine sand w/ clay w/ silt | 300 | 320 |
| Fine to coarse gravel | 320 | 395 |
| Fine sand w/ clay | 395 | 400 |

SUPPLEMENTAL DRILLING LOG ATTACHED YES NO
 PAGE 1 OF _____
 COMPANY NAME Summa Drilling Co.
 SIGNATURE OF DRILLER IN CHARGE [Signature]