

SIT NO 68880 LOCAL ID _____

OWNER James Whitman

INSTALLATION DATE _____
 TEST PERMANENT

- DOMESTIC AGRICULTURAL
- COMMERCIAL INDUSTRIAL
- IRRIGATION PUBLIC
- MONITOR DEWATERING
- HEAT PUMP RECHARGE HEAT PUMP SUPPLY
- OTHER (Specify) _____

HAS A REPLACEMENT WELL? YES NO
INDONMENT DATE FOR OLD WELL _____
INDONMENT METHOD _____

- DRILLING METHOD**
- AUGERED CORED CABLE TOOL
 - DRIVEN JETTED AIR ROTARY
 - MUD ROTARY REVERSE WASHED

OTHER (Specify) _____
TOTAL DEPTH DRILLED 365'

CASING SEQUENCE

DEPTH	DIAMETER	MATERIAL
0 - 2'	4"	STEEL
2' - 370'	3 7/8"	PVC
370' - 360'	3 7/8"	PVC
360' - 365'	3 7/8"	PVC

SCREEN SEQUENCE

DEPTH	DIAMETER	MATERIAL
0 - 340'	3 7/8"	STEEL
340' - 360'	3 7/8"	PVC
360' - 365'	3 7/8"	PVC

WRITTEN APPROVAL FOR SCREENING/
GRAVEL PACKING MORE THAN ONE ADU-
PER MUST BE OBTAINED FROM DNR/EC.

OUT TYPE: CEMENT BENTONITE CLAY

HEIR: _____
 CM: 0 TO 310 FEET
 M-GROUT BACKFILL OF WELL ANNULUS
 FE: _____ FROM _____ TO _____ FEET
 TAVEL PACK: TYPE MASS II
 IOM: 310 TO 365 FEET
 TATIC WATER LEVEL: DATE _____
10 FT. (Below) GROUND SURFACE
 JUMPING WATER LEVEL: 28 FT. BELOW GRADE
 TER: 2.5 HOURS AT _____ C/M.

WELL HEAD COMPLETION:

INC. PITLESS ADAPTOR
7 CAPSACK
7 INCHES ABOVE GRADE

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE W/A

RATED CAPACITY (GPM) _____ FT. BELOW GRADE
PUMP INTAKE SETTING _____

THE COMPLETED WELL IS?

- A. AT LEAST 5' FROM ANY OVERHANG YES NO
- B. AT LEAST 50' FROM ANY SEPTIC TANK YES NO
- C. AT LEAST 10' FROM TOWN SEWER LINE YES NO
- D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD YES NO

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY

IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM? YES NO

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

RECEIVED

OCT 30 1987

WATER SUPPLY

guy
R33-72

DRILLERS LOG DESCRIPTION

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
TOP SOIL	0	1
fn snd & cly	1	18
gry cly	18	27
fn/md snd	27	91
bl cly	91	128
fn snd & cly	128	160
bl cly	160	180
fn/crse snd & gry	180	240
gry cly	240	268

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO

PAGE 1 OF _____ PAGES
 COMPANY NAME American Water Well Sys
 SIGNATURE OF DRILLER IN CHARGE: Se Wells DATE 7/2

PLANT NO. 68880

LOCAL ID

Rj 32-72

OWNER James Wharton

DESCRIPTION

TOP OF STRATA

BOTTOM OF S

cly & fn snd	268	310
fn/crse snd	310	360
fn snd & cly	360	365

OTHER COMMENTS:

RECEIVED

OCT 30 1987

WATER SUPPLY