BEST AVAILABLE COPY

Sheet 1 of 1

CLIENT Miami-Dade Water & Sewer Authority Date 1/23/80
Well No. I-3 Project No. BC55900.92

☐ Electric ☐ Caliper
☐ Gamma Ray ☐ Fluid Resistivity
☒ Temperature ☐ Fluid Velocity

69/362

Location: State Florida County Dade
SW ¼ SE ¼ NE ¼ Sec. 21 T. 56 ☐ N ☒ S R 40 ☒ E ☐ W
Logged by J. Lehnen Observer

Owner: Miami-Dade Water & Sewer Authority
Well: I-3
Driller: Alsay-Pippin Corp. Date Drilled: 1979
Surface Elevation: 9.42 ft. ☐ Estimated ☐ Measured Above MSL
T.D. Logged 2,625' T.D. Driller
Hole Dia. From To Dia. From To
Casing I. D. 34" From 0 To 1800' Dia. 24" From 0 To 2629'
Finish: ☐ Open hole ☐ Screen ☐ Gravel ☐ Other
Water Level: ft: ☐ Above ☐ Below MP, at ☐ Above ☐ Below Land Surface
Yield: Flow gpm Pump gpm
Drawdown: ft. after hours pumping @ gpm
Use: ☐ Dom. ☐ Stock ☐ PS ☐ Ind. ☐ Irr. ☐ Test ☐ Heating or cooling ☐ Drainage ☒ Disposal ☐ Obs.

Water Quality:
Temp. °F; Sp. Cond. ; Iron ppm
Cl⁻ ppm; $SO_4^{=}$ ppm; Total Hardness ppm
Color Odor Taste

Log Scales

Electric Log	Fluid Resistivity
SP millivolts/inch Res. ohm-meters/inch Res. ohms/inch	ohm-meters/inch @ °F
Gamma Ray Log	**Fluid Velocity**
Counts/sec/in. Time Constant sec. Logging speed FPM	Counts/min/inch FPM (continuous) Q = gpm
Temperature	**Caliper**
70 °F to 170 °F Logging speed 30 FPM	inches to inches Logging speed FPM

Water Samples
Depths sampled: , , , , ,

CH2M HILL
Water Resources Division
P.O. Box 1647
Gainesville, Florida 32602
(904) 377-2442

Remarks: Temperature after first stage cementing of 24" casing
Measuring point: zero at pad level

FE 1029

GEOPHYSICAL WELL SURVEY