



FLUID CONDUCTIVITY TEMPERATURE LOG

868734

Company: HAZEN & SAWYER, P.C.
 Well: CONCENTRATE DISPOSAL #1
 Field: COOPER CITY
 County: BROWARD
 State/Prv: FLORIDA

Company: HAZEN & SAWYER
 Well: CONCENTRATE #1
 Field: COOPER CITY
 County: BROWARD
 State/Prv: FLORIDA

Location: [Blank]
 Other Services: SEE COMMENTS
 Permanent Datum: PAD
 Log Measured From: PAD
 Drilling Measured From: PAD
 Elevation: [Blank]
 K.B. [Blank]
 D.F. [Blank]
 G.L. [Blank]

Date	15-JAN-2001
Run Number	0010
Depth Driller	EGHT
Depth Logger	2039
Bottom Logged Interval	2022
Top Log Interval	1000'
Open Hole Size	12.25"
Type Fluid	WATER
Density / Viscosity	NA
Max. Recorded Temp.	74 DEGF
Estimated Cement Top	NA
Time Well Ready	00:00
Time Logger on Bottom	00:00
Equipment Number	102 FTM
Location	FTMERS
Recorded By	LEE
Witnessed By	M MYERS


Run Number	ONE	From	260'	To	260'	Weight		From	To
ONE	SURFACE	260'	1039'						
TWO	CASING	1039'	995'						
THREE	CASING	995'	2039'						
FOUR	CASING	2039'							

Casing Record	Size	Weight	Top	Bottom
Surface String	50"	300 WT	SURFACE	40'
Pick String	50"	300 WT	SURFACE	250'
Production String	42"	375 WT	SURFACE	985'
Liner				

All interpretations are opinions based on inferences from electrical or other measurements and we cannot and do not guarantee the accuracy or correctness of any interpretation, and we shall not, except in the case of gross or willful negligence on our part, be liable or responsible for any loss, costs, damages, or expenses incurred or sustained by anyone resulting from any interpretation made by any of our officers, agents or employees. These interpretations are also subject to our general terms and conditions set out in our current Price Schedule.

Comments


OTHER SERVICES:
 FLOWMETER
 TELEVISION SURVEY
 (PACKER SET @ 1000')




FLORIDA STATIC & DYNAMIC (550 GPM)

GEOPHYSICAL LOGGING, INC.

Database File: cciw1.db
 Dataset Pathname: run8/pass4
 Presentation Format: frt_mg.prs
 Dataset Creation: Mon Jan 15 23:15:57 2001 by Log VER_5.4
 Charted by: Depth in Feet scaled 1:240





FRT Calibration Report

Serial Number:	30	
Tool Model:	SONDEX	
Performed:	Thu Sep 14 09:05:49 2000	
Point #	Reading	Reference
1	0.000 cps	0.000
2	39.356 cps	750.000
3	292.001 cps	10000.000
4	1691.660 cps	50000.000
5		
6		

Temperature Calibration Report

Serial Number:	30	
Tool Model:	SONDEX	
Performed:	Thu Sep 14 09:05:45 2000	
Point #	Reading	Reference
1	135.064 cps	38 degF
2	313.422 cps	76 degF
3	577.828 cps	130 degF