



**YOUNGQUIST  
BROTHERS, Inc**

GEOPHYSICAL LOGGING DIVISION

**FLUID CONDUCTIVITY  
TEMPERATURE  
SOUTHDISTRICT**

2009 APR 13 A 9:44

Company CHARLOTTE COUNTY UTILITIES  
Well IW-2  
Field BURNT STORE WWTP  
County CHARLOTTE  
State FL

Company CHARLOTTE COUNTY UTILITIES  
Well IW-2  
Field BURNT STORE WWTP  
County CHARLOTTE State FL

Location  
Permanent Datum MALCOLM PIRNIE/  
Log Measured From MCNABB HYDROGEOLOGICAL  
Drilling Measured From

Elevation  
K.B.  
D.F.  
G.L.

Date	29-JULY-2008	
Run Number	THIRTEEN	
Depth Driller	3002'	
Depth Logger	3002'	
Bottom Logged Interval	3002'	
Top Log Interval	CASING	
Open Hole Size	22"	
Type Fluid	WATER	
Density / Viscosity	NA	
Max. Recorded Temp.	NA	
Estimated Cement Top	SURFACE	
Time Well Ready	1100	
Time Logger on Bottom	1130	
Equipment Number	103	
Location	FT MYERS CATHY	
Recorded By	M. BLACK	
Witnessed By		


Borehole Record		Borehole Record	
Run Number	Bit	From	To
ONE	12.25"	SURFACE	250'
TWO	64"	SURFACE	224'
THREE	14.75"	CASING	775'
FOUR	52"	CASING	715'
		Size	Wgt/ft
		54"	3.75" W.T.
		44"	3.75" W.T.
		34"	3.75" W.T.
		24"	5.00" W.T.
		18"	FRP

<<< Fold Here >>>

All interpretations are opinions based on inferences from electrical or other measurements and we cannot and do not guarantee the accuracy or correctness of any interpretation, and we shall not, except in the case of gross or willful negligence on our part, be liable or responsible for any loss, costs, damages, or expenses incurred or sustained by anyone resulting from any interpretation made by any of our officers, agents or employees. These interpretations are also subject to our general terms and conditions set out in our current Price Schedule.

**Comments**


OTHER SERVICES:  
  
X-Y CALIPER / GAMMA RAY  
DUAL INDUCTION  
SONIC  
CBL  
VIDEO



**YOUNGQUIST  
BROTHERS, Inc**  
GEOPHYSICAL LOGGING DIVISION

**FLUID CONDUCTIVITY / TEMP**

Database File: btstow2.db  
Dataset Pathname: run13/pass1  
Presentation Format: frtemp  
Dataset Creation: Tue Jul 29 11:17:41 2008 by Log 6.2\_B4



100.8

2700

63213

100.9

61110

100.9

62458

2750

100.9

62326

100.9

63410

100.9

2800

63083

100.9

63672

100.9

63652

2850

100.9

63588

100.9

63380

100.9

2900


63717

100.9

61731

100.9

63753



### FRT Calibration Report

Serial Number: 31  
 Tool Model: SONDEX  
 Performed: Mon Jun 09 10:53:41 2008

Point #	Reading		Reference
1	31.165	cps	1000.000
2	167.193	cps	10000.000
3	415.824	cps	25000.000
4	918.476	cps	50000.000
5		cps	
6		cps	

### Temperature Calibration Report

Serial Number: 31  
 Tool Model: SONDEX  
 Performed: Mon Jun 09 10:53:33 2008

Point #	Reading		Reference	
1	152.99	cps	39	degF
2	330.989	cps	82	degF
3	688.237	cps	157	degF

