



FLUID RESISTIVITY
TEMPERATURE
LOG

Company Diversified Drilling Corporation

Well ASR No. 3

Field Punta Gorda

County Charlotte State/Prv Florida

City of Punta Gorda
Water Treatment Plant

Other Services
XY/GR
DIL,BHC
FRT

Permanent Datum G.L.
Log Measured From G.L.
Drilling Measured From G.L.

Elevation

Elevation
K.B.
D.F.
G.L.

Date 8-JAN-2002

Run Number SIX

Depth Driller 1000'

Depth Logger 1007'

Bottom Logged Interval 999'

Top Log Interval 775'

Open Hole Size 15"

Type Fluid WATER

Density / Viscosity NANA

Max Recorded Temp. NA

Estimated Cement Top NA

Time Well Ready 07:00 1/8/02

Time Logger on Bottom 12:00 1/8/02

Equipment Number MVGS-1

Location Ft. Myers

Recorded By S. Miller

Witnessed By P.D.Amo (MWH)

B. Bahner (DDC) C. Godwin (DDC)

<<< Fold Here >>>

All interpretations are opinions based on inferences from electrical or other measurements and we cannot and do not guarantee the accuracy or correctness of any interpretation, and we shall not, except in the case of gross or willful negligence on our part, be liable or responsible for any loss, costs, damages, or expenses incurred or sustained by anyone resulting from any interpretation made by any of our officers, agents or employees. These interpretations are also subject to our general terms and conditions set out in our current Price Schedule.

Comments

STATIC (since 12:00, 1/7/02) and DYNAMIC down passes performed.
Rm=3.091 ohm-m @ 86.0 degF (DYNAMIC). Q=728 gpm.

FLUID RESISTIVITY CALIBRATION REPORT


(Performed: 14-DEC-01 15:30)

OHM-M	CPS
2.230	2252.61
3.082	2445.45
4.895	2900.12

TEMPERATURE CALIBRATION REPORT


(performed: 14-DEC-01 15:45)

DEG-F	CPS
36.1	2172.13
151.8	5684.71




DYNAMIC FRT DOWN

Database File: pgasr-3.db
Dataset Pathname: run6/DFRT
Presentation Format: frtpg2.prs
Dataset Creation: Tue Jan 08 15:19:38 2002
Charted by: Depth in Feet scaled 1:240



TEMPERATURE (degF) 90
 -0.5 DELTA TEMP (degF) 0.5

Fluid Resistivity 5



STATIC FRT DOWN

Database File: pgasr-3.db
 Dataset Pathname: run6/SFRT
 Presentation Format: frtpg2.prs
 Dataset Creation: Tue Jan 08 15:18:55 2002
 Charted by: Depth in Feet scaled 1:240

80 TEMPERATURE (degF) 90
 -0.5 DELTA TEMP (degF) 0.5

0 Fluid Resistivity 5

