



YOUNGQUIST BROTHERS, Inc
GEOPHYSICAL LOGGING DIVISION

HIGH RESOLUTION TEMPERATURE LOG

Company **THE ISLAND WATER ASSOCIATION**
Well **IW #1**
Field **SANIBEL ISLAND ROWTP**
County **LEE** State **FLORIDA**

Company **THE ISLAND WATER ASSOC.**
Well **IW #1**
Field **SANIBEL ISLAND**
County **LEE**
State **FLORIDA**

Location
Permanent Datum
Log Measured From
Drilling Measured From
Elevation
Other Services
RTS
VIDEO
APT
Elevation
K.B.
D.F.
G.L.


Date	7-OCT-2009	
Run Number	MIT '09	
Depth Driller	3235'	
Depth Logger	3223'	
Bottom Logged Interval	3223'	
Top Log Interval	SURFACE	
Open Hole Size	22"	
Type Fluid	WATER	
Density / Viscosity	NA	
Max. Recorded Temp.	89 F	
Estimated Cement Top	NA	
Time Well Ready	1000	
Time Logger on Bottom	1000	
Equipment Number	103	
Location	FT. MYERS	
Recorded By	CATHEY	
Witnessed By	R. BLIND	

	Borehole Record		Run No.	Borehole Record	
	Bit	From		Bit	To
Casing Record					
Surface String					
Prot. String					
Production String					
Liner					
Size					
Wgt/Ft					
Top					
Bottom					

<<< Fold Here >>>




All interpretations are opinions based on inferences from electrical or other measurements and we cannot and do not guarantee the accuracy or correctness of any interpretation, and we shall not, except in the case of gross or willful negligence on our part, be liable or responsible for any loss, costs, damages, or expenses incurred or sustained by anyone resulting from any interpretation made by any of our officers, agents or employees. These interpretations are also subject to our general terms and conditions set out in our current Price Schedule.



Comments




TEMPERATURE

Database File: sanbel09.db
 Dataset Pathname: MIT09/TEMP
 Presentation Format: temp
 Dataset Creation: Wed Oct 07 07:49:27 2009 by Log 6.2_B4
 Charted by: Depth in Feet scaled 1:600










1250
1300
1350
1400
1450
1500
1550
1600
1650
1700
1750
1800
1850

86.9
87.0
87.0
87.1
87.1
87.1
87.2
87.2
87.3
87.4
87.4
87.4
87.4
87.5
87.6
87.6
87.6
87.7
87.7
87.8
87.7
87.9
88.0
88.1
88.1
88.1
88.2
88.2
88.3
88.4





1900
1950
2000
2050
2100
2150
2200
2250
2300
2350
2400
2450
2500



2550

2600

2650

2700

2750

2800

2850

2900

2950

3000

3050

3100

88.4

88.2

88.1

88.0

88.0

88.0

88.1

88.1

87.6

87.4

87.3

87.5

87.8

88.1

88.3

88.3

88.2

88.0

88.0

87.6

87.4

87.4

87.3

87.2

87.0

86.8

87.1

87.2


87.2



87.3

87.3


87.3

87.3





Temperature Calibration Report					
Serial Number:			954		
Tool Model:			RTS		
Performed:			Mon Mar 16 16:57:31 2009		
Point #	Reading		Reference		
1	338	cps	34		degF
2	789.32	cps	78		degF
3	1553.26	cps	152		degF



TEMP 0.10 ft

Dataset: MIT09/TEMP
Total Length: 25.50 ft
Total Weight: 70.00 lb
O.D. 1.69 in