

# MV Geophysical

## FLUID CONDUCTIVITY TEMPERATURE LOG

2007 APR 19 4:00 PM

REC'D  
REP

Company	Diversified Drilling Corp.	Company	Diversified Drilling Corporation
Well	Pelican Bay ASR-1	Well	Pelican Bay ASR-1
Field	Naples	Field	Naples
County	Collier	County	Collier
State/Prv	Florida	State/Prv	Florida
Location	Livingston Road Pelican Bay ASR Site Water Resource Solutions, Inc.		Other Services FCT FLO
Permanent Datum	G.L.	Elevation	K.B. D.F. G.L.
Log Measured From	G.L.		
Drilling Measured From	G.L.		

Date	18-AUG-2006	
Run Number	FOUR	
Depth Driller	791'	
Depth Logger	789'	
Bottom Logged Interval	789'	
Top Log Interval	535'	
Open Hole Size	12.25"	
Type Fluid	H2O	
Density / Viscosity	NA/NA	
Max. Recorded Temp.	see FCT log	
Estimated Cement Top	NA	
Time Well Ready	ROA 8/18/2006	
Time Logger on Bottom	17:30 8/18/2006	
Equipment Number	MVG-S-1	
Location	Ft. Myers	
Recorded By	S. Miller	
Witnessed By	A. McTherina (WRS)	C. Sappington (DDC)
		Travis/T. T. (DDC)
Borehole Record		
Run Number	Bit	From
ONE	12.25"	39'
TWO	32"	39'
THREE	12.25"	320'
		789' Logger
Tubing Record		
Casing Record	Size	Wgt/Ft
Surface String	34"	3.75" WT
Prod. String	26"	3.75" WT
Production String		
Liner		
Invoice No.	2006246	P.O. # 61071
		Job No. 6604
		* FINAL PRINT *

All interpretations are opinions based on inferences from electrical or other measurements and we cannot and do not guarantee the accuracy or correctness of any interpretation, and we shall not, except in the case of gross or willful negligence on our part, be liable or responsible for any loss, costs, damages, or expenses incurred or sustained by anyone resulting from any interpretation made by any of our officers, agents or employees. These interpretations are also subject to our general terms and conditions set out in our current Price Schedule.

### Comments


A DYNAMIC DOWN pass was performed.  
 Cw=6070 uS/cm @ 83.3 degF (Dynamic Sample). Q =~210 gpm.  
 FLUID RESISTIVITY CALIBRATION REPORT (Performed: 22-JULY-06 12:45))

uS/cm	CPS
3033.25	2921.17
5822.2	2562.58
14871.8	2219.58

### TEMPERATURE CALIBRATION REPORT (Performed: 22-JULY-06 12:15)

DEG-F	CPS
34.4	2345.78
143.1	6968.24

Packer Set @ 591'



# DYNAMIC FCT DOWN



Database File: pbasr-1.db  
 Dataset Pathname: run5/DFCT  
 Presentation Format: fctpbay2.prs  
 Dataset Creation: Fri Aug 18 20:20:43 2006  
 Charted by: Depth in Feet scaled 1:240


2007 APR 19 4:00 PM  
 ULUS  
 2007

80 TEMP (degF) 90

-0.5 DTMP (degF) 0.5

5800 FLUID CONDUCTIVITY (uS/cm) 6800





<- TD ->

