

MV Geophysical

FLUID RESISTIVITY TEMPERATURE LOG

Company Diversified Drilling Corp.
Well Storage Zone MW-1
Field Punta Gorda
County Charlotte
State/Prv Florida

Company Diversified Drilling Corporation
Well Storage Zone Monitor Well No. 1
Field Punta Gorda
County Charlotte
State/Prv Florida

Location City of Punta Gorda
 Water Treatment Plant

Permanent Datum G.L.
Log Measured From G.L.
Drilling Measured From G.L.

Elevation K.B.
 D.F.
 G.L.

Other Services
 XY/GR, DIL
 BHC, FLOW
 DEVI

Date	17-JAN-2002						
Run Number	THREE						
Depth Driller	803'						
Depth Logger	801'						
Bottom Logged Interval	801'						
Top Log Interval	25'						
Open Hole Size	7.875"						
Type Fluid	WATER						
Density / Viscosity	NANA						
Max. Recorded Temp.	na						
Estimated Cement Top	NA						
Time Well Ready	07:00 1/17/02						
Time Logger on Bottom	07:30 1/17/02						
Equipment Number	IMVGS-1						
Location	Ft. Myers						
Recorded By	S. MILLER						
Witnessed By	P. D'Amo (MWH)						
	Toby (DDC)	B. Balmer (DDC)					
	Borehole Record						
Run Number	Bit	From	To	Size	Weight	From	To
ONE	7.875"	42'	350'				
TWO	22"	42'	355'				
THREE	7.875"	350'	803'				
	Casing Record		Tubing Record				
Surface String	Size	Mgd/Ft	Top	Bottom			
Production String	24"	0.375" WT	SURFACE	42'			
Liner	16"	0.375" WT	SURFACE	350'			
Invoice No.	2002012	P.O. # 13452	Job No. 6022	* FINAL PRINT *			


All interpretations are opinions based on inferences from electrical or other measurements and we cannot and do not guarantee the accuracy or correctness of any interpretation, and we shall not, except in the case of gross or willful negligence on our part, be liable or responsible for any loss, costs, damages, or expenses incurred or sustained by anyone resulting from any interpretation made by any of our officers, agents or employees. These interpretations are also subject to our general terms and conditions set out in our current Price Schedule.

Comments
 STATIC (since 15:00, 1/16/02) and DYNAMIC down passes performed.
 Rm=3.478 ohm-m @ 85.1 degF (DYNAMIC).. Q=728 gpm.
FLUID RESISTIVITY CALIBRATION REPORT
 (Performed: 12-JAN-01 17:30)

OHM-M	CPS
2.575	2950.14
3.404	3185.45
4.829	2565.98

TEMPERATURE CALIBRATION REPORT
 (Performed: 12-JAN-01 17:45)

DEG-F	CPS
39.0	2515.12
105.6	5795.18



DYNAMIC FRT DOWN

Database File: pgmw-4.db
 Dataset Pathname: run3/dfrt
 Presentation Format: frtpg2.prs
 Dataset Creation: Thu Jan 17 14:44:04 2002
 Charted by: Depth in Feet scaled 1:240


80 TEMPERATURE (degF) 90



-0.5 DELTA TEMP (degF) 0.5


0

Fluid Resistivity

5









STATIC FRT DOWN

Database File: pgmw-4.db
 Dataset Pathname: run3/SFRT
 Presentation Format: frtpg2.prs
 Dataset Creation: Thu Jan 17 08:56:12 2002
 Charted by: Depth in Feet scaled 1:240








200




300

400



3.40
3.39
3.39
3.39
3.38
3.38
3.38
3.38
3.38
3.38
3.38
3.38
3.38
3.38
3.38
3.37
3.36
3.36
3.36
3.36
3.32
3.30
3.27
3.27
3.26
3.26
3.28





Total Length:	4.10 ft
Total Weight:	20.00 lb
O.D.	2.00 in