


Owner SNP Mathews Arm # 1 Use Public

Location 8/10 mile N. of milepost # 23 on Skyline Drive, 8/10 W. of Drive
on fire road.



Well Data

Driller: Sydnor
 Completed: 6/17/63
 Total Depth: 200'
 Static W. L.: 17.50' (tape) from top of T. C. casing
 Casing: 6 11/32 x 0' - 59'
 Bedrock: 50'
 10" x 0' - 57'
 Hole Size: 6 1/4" x 57' - 200'
 Yield: 3 GPM
 H₂O Temp: 52° F.
 Aquifers: 68'-69', 94'-95' (driller)
 Elev: 2, 675' (topo)
 Geology: Greenstone

Instrument Data

SP setting 20 Mv Approx. 48'/min.
 Res. " 200 Ohm/m 48'/min.
 .005 Mr 28'/min.
 Gamma " .005 Mr " 28'/min.
 " E-3; G-16
 Fluid: Fresh Water
 Running Time 1 Hrs. 30 Mins.
 Depth of Log: Elec. 198' Gamma 195'
 Ground Electrode 8' below SWL in casing.

Remarks Casing 1.30' from ground level
