


Log # 99 W # 856 County Page - 75 Date 7/3/63

Owner SNP - Mathews Arm #2 Use Public

Location 8/10 mile N. of milepost # 23 on Skyline Drive, 1 2/10 mile W.
of Drive on fire road.



Well Data

Driller: Sydnor

Completed: 6/10/63

Total Depth: 200'

Static W. L.: 5.25' (tape) from top of T. C. " casing

Casing: 6" x 26'3"

Bedrock: 15 10" x 0' - 24'9"

Hole Size: 6 1/4" x 24'9" - 200'

Yield: 23 GPM

H₂O Temp: 52°F.

Aquifers: 42-43, 47-48, 73-76,
109-110 (driller)

Elev: 2,515 (topo)

Geology: Greenstone

Instrument Data

SP setting 50 Mv Approx. 48'/min.

Res. " 200 Ohm/m" 48'/min.

Gamma " .005 Mr " 28'/min.

Gamma " .0025 Mr " 28'/min.

" E-3; G-16

Fluid: Fresh Water

Running Time 2 Hrs. 10 Mins.

Depth of Log: Elec. 196' Gamma 196'

Ground Electrode 5' below SWL in casing

Remarks Casing 1.50' above ground level

Logged By Whitfield and Wilkenloh