

INTERVAL SHEET

Page 1

VDMR WELL NO. 413

Sample Interval: from 10 to 487

PROP: Dupont-Celanese Corp. Narrows, Va. Total Depth: _____

COMP: Va. Pump & Machinery Co.

Oil _____ Gas _____ Water x Exploratory _____

COUNTY: Giles

Cuttings x Core _____ Other _____

From-To	From-To	From-To	From-To	From-To
10 -	<u>300</u> -	-	-	-
20 -	310 -	-	-	-
30 -	320 -	-	-	-
40 -	330 -	-	-	-
50 -	340 -	-	-	-
60 -	345 -	-	-	-
70 -	350 -	-	-	-
80 -	360 -	-	-	-
90 -	370 -	-	-	-
<u>100</u> -	380 -	-	-	-
110 -	390 -	-	-	-
120 -	398 - <u>408</u>	-	-	-
130 -	410 -	-	-	-
140 -	420 -	-	-	-
150 -	430 -	-	-	-
160 -	440 -	-	-	-
170 -	450 -	-	-	-
180 -	460 -	-	-	-
190 -	470 -	-	-	-
<u>200</u> -	480 -	-	-	-
210 -	487 -	-	-	-
220 -	-	-	-	-
230 -	-	-	-	-
240 -	-	-	-	-
250 -	-	-	-	-
260 -	-	-	-	-
270 -	-	-	-	-
280 -	-	-	-	-
290 -	-	-	-	-
295 -	-	-	-	-

Complete set of washed samples

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF CONSERVATION AND ECONOMIC DEVELOPMENT
DIVISION OF MINERAL RESOURCES

Box 3667, University Station, Charlottesville, Virginia

WWCR-#3
VDMR-#413

WATER WELL COMPLETION REPORT

OWNER: Celanese Corp of America Mailing Address: Narrows
 TENANT: _____ Mailing Address: _____
 DRILLER: Va. Machinery & Well Company Mailing Address: (C. G. Hay, driller)
 WELL LOCATION: County Giles Approx. _____ ft. _____ miles
NW (direction) of Pearisburg and _____ ft. _____ miles of _____

(Give direction and distance in feet or tenths of mile from two reference points—roads, towns, rivers, etc.—on county highway or other map)

WATER CONDITIONS

DEPTH

STATIC WATER LEVEL _____

WATER ZONES (fissures or formations supplying water)

(from) _____ (to) _____ (from) _____ (to) _____

_____ ft. _____, _____ ft. _____

_____ ft. _____, _____ ft. _____

QUANTITY OF WATER

WELL PUMPED (or bailed) at 600 + Gal. per Min. with

_____ feet DRAWDOWN after _____ HOURS PUMPING.

FLOW (natural) _____ G.P.M. HEAD _____ ft. (above ground) **W**

REMARKS: _____

QUALITY OF WATER

COLOR _____ TASTE _____

ODOR _____ OTHER _____

ANALYSIS: AVAILABLE— Yes No ATTACHED Yes No

TEMPERATURE _____

WATER (from) _____ ft. (to) _____ ft.

(salt, brackish, iron, sulfur, acid, other)

USE OF WATER: Domestic Town Industry Farm Public

CONSTRUCTION

RIG TYPE (or method) 750 gpm pump capacity
(rotary, cable, bored, driven, etc..)

DATE: Started _____; Completed 1939

TOTAL DEPTH 487'10" ft.

BEDROCK at _____ ft.

GROUTING INFORMATION

METHOD USED _____

GROUTING MATERIAL _____

DEPTH OF GROUTING _____

REMARKS: _____

HOLE SIZE

(diam) _____ in. (from) _____ ft. (to) _____ ft.

16 in. _____ ft. _____ ft.

CASING SIZE

(diam) _____ in. (from) _____ ft. (to) _____ ft.

16 in. 0 ft. 78 ft.

12 in. 78 ft. 444 1/2 ft.

SCREEN (or perforations)

(diam.) _____ in. (from) _____ ft. (to) _____ ft. (opening size)

PUMP (installed)

TYPE _____ Cap. (gpm) 750

H.P. _____ Depth of intake _____ ft.

