

INTERVAL SHEET

Page 1

VDMR Well No.: 525

Date 9/13/61

Sample Interval: from 10 to 416

PROP: Ray Warrick

Total depth _____

COMP: Payne

Oil _____ Gas _____ Water X Exploratory _____

COUNTY: Albemarle (Crozet)

Cuttings X Core _____ Other _____

From-To	From-To	From-To	From-To	From-To
-	10-20	-	-	-
-	20-80	-	-	-
-	80- <u>100</u>	-	-	-
-	100-130	-	-	-
-	130-150	-	-	-
-	150-190	-	-	-
-	190- <u>205</u>	-	-	-
-	205-209	-	-	-
-	209-214	-	-	-
-	214-233	-	-	-
-	233-238	-	-	-
-	238-246	-	-	-
-	246-257	-	-	-
-	257-264	-	-	-
-	264-282	-	-	-
-	282-288	-	-	-
-	288- <u>300</u>	-	-	-
-	300-311	-	-	-
-	311-318	-	-	-
-	318-325	-	-	-
-	325-329	-	-	-
-	329-340	-	-	-
-	340-357	-	-	-
-	357-368	-	-	-
-	368-386	-	-	-
-	386-393	-	-	-
-	393-398	-	-	-
-	398-416	-	-	-
-	-	-	-	-
-	-	-	-	-

Not sufficient amount of material to wash

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF CONSERVATION AND ECONOMIC DEVELOPMENT

DIVISION OF MINERAL RESOURCES

Box 3667, University Station, Charlottesville, Virginia

WVCR 786
VDMR 525

WATER WELL COMPLETION REPORT


OWNER: Ray Warrick Mailing Address: _____
 TENANT: _____ Mailing Address: _____
 DRILLER: Southern Drilling Co. Mailing Address: Roanoke, Va.
 WELL LOCATION: County Albemarle Approx. _____ ft. miles
 (direction) of Crozet and _____ ft. miles of _____

(Give direction and distance in feet or tenths of mile from two reference points - roads, towns, rivers, etc. - on county highway or other map.)

WATER CONDITIONS

DEPTH
 STATIC WATER LEVEL 40 ?
 WATER ZONES (fissures or formations supplying water)
 (from) (to) (from) (to)
 _____ ft. _____, _____ ft. _____
 _____ ft. _____, _____ ft. _____

QUANTITY OF WATER
 WELL PUMPED (or bailed) at 100 Gal. per Min. with
 _____ feet **DRAWDOWN** after _____ HOURS PUMPING.
 FLOW (natural) _____ G.P.M. HEAD _____ ft. (above ground) **W**
 REMARKS: _____



QUALITY OF WATER

COLOR _____ TASTE _____
 ODOR _____ OTHER _____
 ANALYSIS AVAILABLE - Yes No ATTACHED Yes No
 TEMPERATURE _____
 _____ WATER (from) _____ ft. (to) _____ ft.
(salt, brackish, iron, sulfur, acid, other)
 USE OF WATER: Domestic Town Industry Farm Public

CONSTRUCTION

RIG TYPE (or method) _____
(rotary, cable, bored, driven, etc..)
 DATE: Started _____; Completed Jun. 12, ? '47
 TOTAL DEPTH 365 ft.
 BEDROCK at _____ ft.

HOLE SIZE

CASING SIZE

(diam) in. (from) ft. (to) ft.	(diam) in. (from) ft. (to) ft.
_____	<u>6?</u> in. <u>0</u> ft. <u>40-50?</u> ft.

SCREEN (or perforations)

(diam) (from) (to) (opening size)
 _____ in. _____ ft. _____ ft.

GROUTING INFORMATION

METHOD USED _____
 GROUTING MATERIAL _____
 DEPTH OF GROUTING _____

PUMP (installed)

TYPE _____ Cap. (gpm) _____
 H.P. _____ Depth of intake _____ ft.

REMARKS: Well test Report: 318' for depth of setting, pumping at 51 gpm, draw-down was 138.6 ft. which made a p. level of 178 ft.
Pumping at 100 gpm draw-down was 232 ft which made a p. level of 272

Source of information - Sydnor

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF CONSERVATION AND ECONOMIC DEVELOPMENT

DIVISION OF MINERAL RESOURCES

Box 3667, University Station, Charlottesville, Virginia

1786

W-525

WATER WELL COMPLETION REPORT

OWNER: Ray Warrick Mailing Address: _____

TENANT: Sydnor Mailing Address: _____

DRILLER: Southern Drilling Co. Mailing Address: Roanoke, Va.

WELL LOCATION: County Albemarle Approx. _____ ft. miles

(direction) of Crozet and _____ ft. miles of _____

(Give direction and distance in feet or tenths of mile from two reference points—roads, towns, rivers, etc.—on county highway or other map.)

WATER CONDITIONS

DEPTH 40? - 50?

STATIC WATER LEVEL _____

WATER ZONES (fissures or formations supplying water)

(from) _____ (to) _____, (from) _____ (to) _____

_____ ft. _____ ft.

QUANTITY OF WATER

WELL PUMPED (or bailed) at 100 Gal. per Min. with _____ feet DRAWDOWN after _____ HOURS PUMPING.

FLOW (natural) _____ G.P.M. HEAD _____ ft. (above ground)

REMARKS: _____

QUALITY OF WATER

COLOR _____ TASTE _____

ODOR _____ OTHER _____

ANALYSIS: AVAILABLE— Yes No ATTACHED Yes No

TEMPERATURE _____

_____ WATER (from) _____ ft. (to) _____ ft.

(salt, brackish, iron, sulfur, acid, other)

USE OF WATER: Domestic Town Industry Farm Public

CONSTRUCTION

RIG TYPE (or method) _____ (rotary, cable, bored, driven, etc.)

DATE: Started _____; Completed Jun. 12, '47

TOTAL DEPTH 365 ft. ? 416?

BEDROCK at _____ ft.

GROUTING INFORMATION

METHOD USED _____

GROUTING MATERIAL _____

DEPTH OF GROUTING _____

HOLE SIZE

(diam) _____ in (from) _____ ft. (to) _____ ft.

CASING SIZE

(diam) _____ in (from) _____ ft. (to) _____ ft.

6? 0 40-50?

SCREEN (or perforations)

(diam.) _____ in (from) _____ ft. (to) _____ ft. (opening size)

PUMP (installed)

TYPE _____ Cap. (gpm) _____

H.P. _____ Depth of intake _____ ft.

REMARKS: Well test Report: 318' for depth of setting, pumping at 51 gpm, draw-down was 138.6 ft. which made a p. level of 178 ft.

Pumping at 100 gpm draw-down was 232 ft which made a p. level of 272