

WATER WELL COMPLETION REPORT

Department of Conservation and Economic Development

VIRGINIA DIVISION OF MINERAL RESOURCES

Box 3667, University Station, Charlottesville, Virginia

19
W-0298

OWNER: J. M. Snosley

Address: Gladys

TENENT:

WELL LOCATION: Town Gladys, County Campbell
N (direction) of Gladys and _____ ft. miles of _____

Approx. 1/4 mi. Gladys

(Give directions and distance in feet or tenths of miles from two reference points shown on topographic or county highway maps.)

DRILLER: Falwell Well Corp

Address: Lynchburg, Va.

WATER CONDITIONS

DEPTH

STATIC WATER LEVEL 20

WATER (aquifers):

(from) 70 ft. (to) 71, (from) 110 ft. (to) 115
ft. ft. ft. ft.

YIELD

WELL PUMPED (or bailed) at 4 1/2 P.M. with _____ ft. DRAWDOWN after 1 hrs. PUMPING.

ARTESIAN (natural) FLOW _____ G.P.M.; HEAD _____ ft. (above grnd.)

REMARKS: Water was encountered
2 veins, 1 at 70 to 71' - about
2 gal 5 1/2 gal from

QUALITY OF WATER 110 to 115'

COLOR clear TASTE sl. H.

ODOR none OTHER _____

ANALYSIS: AVAILABLE - Yes No ; ATTACHED - Yes No

TEMPERATURE _____ (from) _____ (to) _____

(salt, brackish, iron, sulfur, acid, other) WATER _____ ft. _____ ft.

USE OF WATER

FOR stone
(domestic, town, industry, irrigation, etc.)

ADEQUACY, PERMANENCE _____

PUMP (installed)

TYPE ? CAPACITY GPM _____

H.P. _____ DEPTH OF INTAKE _____

CONSTRUCTION


RIG TYPE (or method) Ingersoll Rand air drive
(rotary, cable, bored, dug, driven, etc.)

DATE STARTED 3-4-59; COMPLETED 3-6-59

TOTAL DEPTH 120 ft.

BEDROCK at 47 ft.

SURFACE ELEVATION _____ ft.



HOLE SIZE

(diam.) (from) (to)
6 in. 0 ft. 120 ft.

8" 0 50

CASING SIZE

(diam.) (from) (to)
? in. _____ ft. _____ ft.

SCREEN (or perforations)

(diam.) (from) (to) (opening size)
_____ in. _____ ft. _____ ft. _____

OTHER CONSTRUCTION INFORMATION: (gravel pack, depth and size of shot, packer, plugs, etc.)

REMARKS

GROUTING INFORMATION

Method Used: _____

Grouting Materials: _____

Depth of Grouting: _____

Grouted around pipe
from 50' back to 20'
Hole drilled 8" first 50'

Samples sent _____
Log of well (over) _____

LOG


FURNISHED BY

Lloyd Campbell

DATE:

3-6-59

DEPTH (feet)		TYPE OF SOIL OR ROCK PENETRATED (gravel, clay, etc., hardness, color, etc)	REMARKS (water, caving, shot, screen, sample, etc)
FROM	TO		
0	40	Red dirt.	
40	47	light tan soft rock	
47	120	grey sandstone	
		<i>Lynchburg gr?</i>	



COMMONWEALTH OF VIRGINIA
 DEPARTMENT OF CONSERVATION AND ECONOMIC DEVELOPMENT
 DIVISION OF MINERAL RESOURCES

Box 3667, University Station, Charlottesville, Virginia

WWCR 19
 VDMR 298

WATER WELL COMPLETION REPORT

OWNER: J. M. Mosley Mailing Address: Gladys
 TENANT: _____ Mailing Address: _____
 DRILLER: _____ Mailing Address: _____
 WELL LOCATION: County Campbell Approx. 1/4 mi. ft. miles
north (direction) of Gladys and _____ of _____

(Give direction and distance in feet or tenths of mile from two reference points - roads, towns, rivers, etc. - on county highway or other map)

WATER CONDITIONS

DEPTH
 STATIC WATER LEVEL 20
 WATER ZONES (fissures or formations supplying water)
70 (from) 71 (to) 110 (from) 115 (to)
 _____ ft. _____ ft. _____ ft. _____ ft.

QUANTITY OF WATER

WELL PUMPED (or bailed) at 4 1/2 Gal. per Min. with
 _____ feet DRAWDOWN after 1 HOURS PUMPING.
 FLOW (natural) _____ G.P.M. HEAD _____ ft. (above ground) **W**

REMARKS: Water was encountered 2 veins, 1 at
70' to 71' about 2 gal, 2 1/2 gal from 110 to
115'.

QUALITY OF WATER

COLOR clear TASTE O.k.
 ODOR none OTHER _____

ANALYSIS: AVAILABLE - Yes No ATTACHED Yes No

TEMPERATURE _____
 _____ WATER (from) _____ ft. (to) _____ ft.
 (salt, brackish, iron, sulfur, acid, other) **For store**

USE OF WATER: Domestic Town Industry Farm Public

CONSTRUCTION

RIG TYPE (or method) Ingersoll Rand air drill
 (rotary, cable, bored, driven, etc.)
 DATE: Started 3-4-59; Completed 3-6-59
 TOTAL DEPTH 120 ft.
 BEDROCK at 47 ft.

GROUTING INFORMATION

METHOD USED _____
 GROUTING MATERIAL _____
 DEPTH OF GROUTING _____

HOLE SIZE

6 (diam) in. 0 (from) ft. 120 (to) ft.
8" 0 50

CASING SIZE

_____ (diam) in. _____ (from) ft. _____ (to) ft.

SCREEN (or perforations)

_____ (diam.) (from) _____ (to) _____ (opening size)
 _____ in. _____ ft. _____ ft.

PUMP (installed)

TYPE ? Cap. (gpm) _____
 H.P. _____ Depth of intake _____ ft.

REMARKS: Grouted around pipe, from 50' back to 20'
Hole drilled 8" first 50'

